

ROUTT COUNTY REGIONAL BUILDING DEPARTMENT

136 6th Street * P.O. Box 773840 * Steamboat Springs, CO. 80477 * (970) 870-5566 * FAX (970) 879-3992

MEMORANDUM

TO: BUILDING DEPARTMENT STAFF

FROM: MARK W. MARCHUS, C.B.O.

RE: RECESSED CANS IN ONE HOUR GYPSUM WALL BOARD CEILINGS

DATE: SEPTEMBER 18, 2000

Small (less than 16 inches in area) recessed lighting cans of metal construction may be used in one hour fire resistive ceiling assemblies. Total area of the recessed cans shall be less than 100 square inches for any 100 square feet of ceiling area.